



Office of  
Deputy Commissioner  
of Maritime Affairs

## THE REPUBLIC OF LIBERIA LIBERIA MARITIME AUTHORITY

Marine Notice

**FIR-002**  
**Rev. 07/20**

**TO: ALL SHIPOWNERS, OPERATORS, MASTERS AND OFFICERS OF MERCHANT SHIPS, AND AUTHORIZED CLASSIFICATION SOCIETIES**

**SUBJECT: Fire Extinguishing Requirements for Flammable Liquid Lockers including Paint Lockers**

**Reference:** (a) Maritime Regulation 2.36  
(b) SOLAS 1974, as amended, Regulation 10.6.3, Chapter II-2  
(c) **IMO Resolution MSC.13 (57)**

**Supersedes: Marine Notice FIR-002, dated 06/12**

The following changes have been included: **Revised to apply the requirements to all flammable liquid lockers**

### **PURPOSE:**

**IMO Resolution MSC.13 (57)**, issued 11 April 1989, incorporated several amendments regarding paint and flammable liquid storage lockers into the International Convention for the Safety of Life at Sea, 1974 (SOLAS 1974) with effect on 1 February 1992. **MSC.13 (57)** stipulated requirements be established by administrations for fire extinguishing capability in paint lockers and flammable liquid lockers on new and existing vessels. On 1 July 2002, SOLAS 1974, as amended by the 2000 amendments, in Regulation 10.6.3 of Chapter II-2, implement new requirements for paint lockers and flammable liquid lockers on vessels constructed on or after 1 July 2002. This Notice provides the Liberian requirements for flammable liquid lockers on all Liberian flagged ships and based on the Administration's interpretation of the intent of the regulation regarding paint lockers for vessels with a keel laid, or at a similar stage of construction, before 1 July 2002.

### **APPLICABILITY:**

The regulations are applicable to all Liberian flag vessels.

### **REQUIREMENTS:**

#### **1.0 Requirements for Liberian Vessels**

1.1 Existing Vessels with keels laid, or at a similar stage of construction, before 1 February 1992.

- .1 Lockers of 10m<sup>2</sup> (i.e. 5m x 2m) or less in deck area - one portable fire extinguisher located outside the entrance to the space.
- .2 Lockers greater than 10m<sup>2</sup>, but less than 20m<sup>2</sup> in deck area - two portable fire

**1 of 2**

Inquiries concerning the subject of this Notice should be directed to the Office of the Deputy Commissioner, Republic of Liberia, the Liberian International Ship & Corporate Registry, 22980 Indian Creek Drive., Suite 200, Dulles, VA 20166, USA. The most current version of all Marine Notices are available in the Online Library at: <http://www.lisr.com>

- extinguishers located outside the entrance to the space.
- .3 Lockers greater than 20m<sup>2</sup> in deck area - a suitable fixed fire extinguishing system as defined in Section 2.0 below.
- 1.2 Existing Vessels with keels laid, or at a similar stage of construction, on or after 1 February 1992 and before 1 February 1998.
  - .1 Lockers of 10m<sup>2</sup> (i.e. 5m x 2m) or less in deck area - one portable fire extinguisher located outside the entrance to the space.
  - .2 Lockers greater than 10m<sup>2</sup> in deck area - a suitable fixed fire extinguishing system as described Section 2.0 below.
- 1.3 Existing Vessels with keels laid, or at a similar stage of construction, on or after 1 February 1998 but before 1 July 2002.
  - .1 Lockers of 4m<sup>2</sup> (i.e. 2m x 2m) or less in deck area - one portable fire extinguisher located outside the entrance to the space.
  - .2 Lockers greater than 4m<sup>2</sup> in deck area - a suitable fixed fire extinguishing system as described in Section 2.0 below.
- 1.4 New Vessels with keels laid, or at a similar stage of construction, on or after 1 July 2002.
  - .1 Paint lockers shall comply with fire protection requirements found in SOLAS 1974, as amendment 2000, Chapter II, Regulation 10.6.3.1 and 10.6.3.3 as applicable
  - .2 Flammable liquid storage lockers shall comply with the following requirements:
    - .1 Lockers of 4m<sup>2</sup> (i.e. 2m x 2m) or less in deck area shall comply with the requirements in SOLAS 1974, as amended 2000, Chapter II, Reg. 10.6.3.3.
    - .2 Lockers greater than 4m<sup>2</sup> in deck area - a suitable fixed fire extinguishing system as described in Section 2.0 below.

## **2.0 Definitions Apply to This Notice**

- 2.1 Portable Fire Extinguisher - An extinguisher which is designed to be carried and operated by hand and which has a maximum fully charged weight of 23 kg (50.7 pounds). The minimum size for paint and flammable liquid lockers is either:
  - .1 Carbon Dioxide; with a charge of 6.8 kg (15 pounds)
  - .2 Dry Chemical; with a charge of 4.5 kg (10 pounds)
- 2.2 Suitable Fixed Extinguishing System - A system designed to a recognized standard and of a medium and capacity as follows:
  - .1 Carbon Dioxide - for at least 40% of the gross volume of the space protected.
  - .2 Dry Chemical - for at least 0.5 kg/cubic meter of the gross volume of the space protected.
  - .3 Water Spray with at least 5 liters/square meter of deck area/minute.

\* \* \* \* \*